Lovely Heritage School

Pocket-E, Phase-II, Mayur Vihar, Delhi-110091

E-mail: lovelyheritageschool@gmail.com **Phone:** 011-71572500

Ref. No. : LHS/MV/UT/2025/196 Date : 14-05-2025

UNDERTAKING

I hereby undertake that the Delhi Jal board is not issuing the prescribed **perfoma for safe drinking water and sanitary condition certificate**. So we are the submitting the latest water test report issued by Delhi Jal Board.

Head of the School
Lovely Heritage School
Pocket-E, Mayur Vihar Phase-II,
Delhi-110091

Diary No. 238 dt 29/4/2025

Delhi Jal Board

No.DJB/QCLTYR/PD/250409

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY, TRANS YAMUNA REGION TAHIRPUR DELHI-110093

स्वच्छ भारत
एक कदम स्वच्छता की ओर

NO: DJB/ACWA(TYR)/2025…….

DATE:- 28-04-2025

Analysis report of DJB water supply samples collected from (1) Inlet, (2) Outlet of M/S LOVELY HERITAGE SCHOOL, POCKET-E, PHASE-II, MAYUR VIHAR, DELHI-110091 for drinking purpose.

Ref. No. LHS/MV/2025-26/WT/189, dated: - 21.04.2025
Challan No: - 34, dated: - 22.04.2025

Date of collection : 25-04-2025

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	…	…	-	Clear	Clear
2.	Odour	…	…	-	Chlor.	Chlor.
3.	Turbidity	1.0	5.0	NTU	2.18	2.46
4.	pH Value	6.5-8.5	--	-	7.5	7.5
5.	Electrical Conductivity	--	--	µs/cm	219	388
6.	Total Dissolved Solids	500	2000	mg/l	142	252
B.	Chemical Examination					
7.	P^{th} Alkalinity	…	…	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	78	122
9.	Total Hardness	200	600	mg/l	84	126
10.	Calcium as (Ca)	75	200	mg/l	24.0	36.0
11.	Magnesium as (Mg)	30	100	mg/l	5.76	8.64
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite	….	….	mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	2.06	2.86
15.	Sulphate	200	400	mg/l	29.78	34.16
16.	Chloride	250	1000	mg/l	08	22
17.	Fluoride	1.0	1.5	mg/l	0.26	0.34
18.	Total Iron	1.0	NR	mg/l	0.10	0.16
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	1.00	0.70
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, both water samples conform BIS: 10500-2012 and can be considered fit for drinking purpose.

28/4/25
(B.K Verma)
ACWA(TYR)
Asstt. Chief Water Analyst
D.J.B. Govt. of N.C.T. of Delhi
lity Control Zonal Laboratory (Tyr
hir Pur Dilshad Garden, Delhi-93

28/4/25
(A.G Susmitha)
BACTERIOLOGIST

28/4/2025
(Gulesh Jainar)
CHEMIST

28.04.2025
(Mayank Yadav)
A/CHEMIST

Head of the School
Lovely Heritage Scho
Pocket-E, Mayur Vihar Phase-I
Delhi-110091

MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
SHAHDARA (SOUTH) ZONE
419 1st Floor, UDYOG SADAN
PATPARGANJ INDUSTRIAL AREA DELHI-110092

No. : DHO/Shd.(S)/2025/D-701 Date: 30/11/25

School Health Certificate

1.	Name of School	: Lovely Heritage School
2.	Location of the School	: Pocket-E, Mayur Vihar Phase-II, Delhi-110091
3.	Timing of School	: 8:00 A.M to 1:00 P.M
4.	No. of Students	: 385
5.	No. of Staff	: 31
6.	No. of Rooms	: 58
7.	No. of Doors in each room	: 2 Door & 2 Windows in each room
8.	No. of Fans in each room	: 4 Fans Provided in each room
9.	Desk/Chair	: Provided
10.	No. of Urinals for Boys	: 20
11.	No. of Toilets for Girls	: 18
12.	Building Structure	: Pucca
13.	Drinking Water	: DJB Water Supply
14.	Electricity	: BSES

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

30/11/25
Deputy Health Officer
Shahdara (South) Zone

DEPUTY HEALTH OFFICER
MUNICIPAL CORPORATION OF DELHI
SHAHDARA (SOUTH) ZONE

Head of The School
Lovely Heritage School
Pocket-E, Mayur Vihar Phase-II,
Delhi-110091

Head of the School
Lovely Heritage School
Pocket-E, Mayur Vihar Phase-II
Delhi-110091